

Tele: 23793509

Policy Letter No 25/2012
Directorate General Married
Accommodation Project (DG MAP)
Engineer-in-Chief's Branch,
Integrated HQ of MoD (Army)
Kashmir House, Rajaji Marg,
DHQ PO, New Delhi-110011

21379/Spec Ph-III/P&S/24/MAP

23 Jul 2012

(All PMs & DEPMCs)

SPECIFICATIONS: PRESSURE GAUGE (FIRE FIGHTING)

1. Refer this Headquarters letter No 21378/Vendor PH-III/P&S/03/MAP dt 29 Jun 2012.
2. Given in the succeeding sub paragraph is the specification for Pressure Gauge (Fire Fighting) for the future projects of MAP Phase-II & Phase-III:-
 - (a) The Pressure Gauge shall be constructed of die cast aluminum. It shall be weather proof with an IP 55 enclosure. It shall be a stainless steel bourden tube type. Pressure Gauge will have a scale range from 0 to 16 kg/cm square and shall be constructed as per IS : 3624.

(JS Sodhi)
Lt Col
SO 1 (P&S)
for DG MAP

Internal

Team 'A'	-	for necessary action please
Team 'B'	-	-do-
Contract Section Team 'A'	-	-do-
Contract Section Team 'B'	-	-do-
Arch Section	-	-do-