

Tele: 23793509

**Policy Letter No 29/2012**

Directorate General Married  
Accommodation Project (DG MAP)  
Engineer-in-Chief's Branch,  
Integrated HQ of MoD (Army)  
Kashmir House, Rajaji Marg,  
DHQ PO, New Delhi-110011

21379/Spec Ph-III/P&S/28/MAP  
-----  
-----  
-----

23 Jul 2012

(All PMs & DEPMCs)

**SPECIFICATIONS: EXTERNAL HOSE CABINETS (FIRE FIGHTING)**

1. Refer this Headquarters letter No 21378/Vendor PH-III/P&S/03/MAP dt 29 Jun 2012.
2. Given in the succeeding sub paragraph is the specification for External Hose Cabinets (Fire Fighting) for the future projects of MAP Phase-II & Phase-III:-
  - (a) Each hydrant / Fire Brigade inlet shall be housed in a Hose Cabinet of 1.0m x 0.45m x 0.45m. The Hydrant Cabinet shall hold single headed hydrant, 2Nos Hoses and 1No Branch pipes or Fire Brigade inlets. The sheet shall be powder coated with red paint. The words "Yard Hydrant", "Hydrant" etc. shall be painted in white (or red on the glass) in 75mm high letters. The hose box shall be lockable with socket spanner. All horizontal surfaces shall be sloped adequately with water discharge holes. Vents shall also be located on sides of the Hose Box. A brick pedestal with brick wall complete with plaster shall also be constructed for supporting the hose box. All surfaces shall be plastered with 1:4 ratio (1 cement: 4 fine sand) mortar.

(JS Sodhi)  
Lt Col  
SO 1 (P&S)  
for DG MAP

**Internal**

Team 'A'	-	for necessary action please
Team 'B'	-	-do-
Contract Section Team 'A'	-	-do-
Contract Section Team 'B'	-	-do-
Arch Section	-	-do-