

Tele: 23793509

Policy Letter No 06/2012

Directorate General Married
Accommodation Project (DG MAP)
Engineer-in-Chief's Branch,
Integrated HQ of MoD (Army)
Kashmir House, Rajaji Marg,
DHQ PO, New Delhi-110011

21379/Spec Ph-III/P&S/ /MAP

Jul 2012

(All PMs & DEPMCs)

SPECIFICATIONS: MODULAR SWITCHES

1. Refer this Headquarters letter No 21378/Vendor PH-III/P&S/03/MAP dt 29 Jun 2012.
2. Given in the succeeding sub paragraph is the specification for Modular Switches for the future projects of MAP Phase-II & Phase-III:-

(a) All switches and sockets are modular type which shall be made of fire retardant, self extinguishing poly carbonate plastic, able to withstand the glow wire test at 960 degree celcius. The switches shall conform to IS 3854:1997. The internal design of terminals and contact shall make the switch capable of high overload conditions. The switch shall be of flush type with silver inlay contact on pure copper. All 5 and 15 Amp switches shall be modular type of 240 volts AC grade. All switches shall be fixed on modular plates. All sockets shall be fully modular type. All 5 Amp socket shall be 3 pin type. All 15 Amp socket shall be 6 pin type suitable for 15/5 Amp.

(JS Sodhi)
Lt Col
SO 1 (P&S)
for DG MAP

Internal

Team 'A'	-	for necessary action please
Team 'B'	-	-do-
Contract Section Team 'A'	-	-do-
Contract Section Team 'B'	-	-do-
Arch Section	-	-do-