

Tele: 23793509

**Policy Letter No 11/2012**

Directorate General Married  
Accommodation Project (DG MAP)  
Engineer-in-Chief's Branch,  
Integrated HQ of MoD (Army)  
Kashmir House, Rajaji Marg,  
DHQ PO, New Delhi-110011

21379/Spec Ph-III/P&S/09/MAP

10 Jul 2012

-----  
-----  
-----

(All PMs & DEPMCs)

**SPECIFICATIONS: MCB DISTRIBUTION BOARD INSIDE DWELLING UNIT**

1. Refer this Headquarters letter No 21378/Vendor PH-III/P&S/03/MAP dt 29 Jun 2012.
2. Given in the succeeding sub paragraph is the specification for MCB Distribution Board inside the Dwelling Unit for the future projects of MAP Phase-II & Phase-III:-

(a) MCB Distribution Board of suitable outgoings shall be used. Supply and erection of triple/single pole and neutral distribution board (conforming to IS: 13032 and UEC standard of IP-20) shall be surface/ flush mounted as required. This shall be made from 18 guage sheet steel/ CRCA with stove enamel paint/powder coated. suitable for incorporating incoming MCB with required number of outgoing MCBs with electrolytic copper busbar of 100A per phase and shall be erected on angle iron frame complete (similar to MDS serial 3000 DB).

(JS Sodhi)  
Lt Col  
SO 1 (P&S)  
for DG MAP

**Internal**

Team 'A'	-	for necessary action please
Team 'B'	-	-do-
Contract Section Team 'A'	-	-do-
Contract Section Team 'B'	-	-do-
Arch Section	-	-do-