SPECIFICATIONS: CAST IRON/ MILD STEEL BOXES

- 1. Refer this Headquarters letter No 21378/Vendor PH-III/P&S/03/MAP dt 29 Jun 2012.
- 2. Given in the succeeding sub paragraphs are the specifications for cast iron/mild steel boxes for the future projects of MAP Phase-II & Phase-III:-
  - (a) The boxes having various fitting such as switches, sockets regulators, etc, shall be of cast iron/mild steel of required size and flush mounting type. Average thickness of cast iron boxes should not be less than 2.5 mm and that of MS boxes not less than 2mm thick. The cast iron/ms boxes shall be embedded in the wall and need not be fixed to wooden plugs. The contracts may at his discretion provide galvanized screws without any adjustment.
  - (b) The cast iron/mild steel boxes should be as per IS: 5133 (Part-I): 1969.

(JS Sodhi) Lt Col SO 1 (P&S) for DG MAP

## Internal

(All PMs & DEPMCs)

Team 'A' - for necessary action please

Team 'B' - -do-

Contract Section Team 'A' - -do-

Contract Section Team 'B' - -do-

Arch Section - -do-