

Tele: 23793509

Policy Letter No 20/2012
Directorate General Married
Accommodation Project (DG MAP)
Engineer-in-Chief's Branch,
Integrated HQ of MoD (Army)
Kashmir House, Rajaji Marg,
DHQ PO, New Delhi-110011

21379/Spec Ph-III/P&S/19 /MAP

13 Jul 2012

(All PMs & DEPMCs)

SPECIFICATIONS: CEILING ROSES

1. Refer this Headquarters letter No 21378/Vendor PH-III/P&S/03/MAP dt 29 Jun 2012.
2. Given in the succeeding sub paragraph is the specification for ceiling roses for the future projects of MAP Phase-II & Phase-III:-
 - (a) Ceiling rose shall be of bakelite and shall comply with IS-371 specification for ceiling roses having two or three terminal plates and of out side diameter not less than 63.5mm. The flexible cord shall be fixed to ceiling rose in such a way that no weight is carried by the clamping screws. The flexible cord shall be of 23/0076 dia cord with copper conductor.

(JS Sodhi)
Lt Col
SO 1 (P&S)
for DG MAP

Internal

Team 'A'	-	for necessary action please
Team 'B'	-	-do-
Contract Section Team 'A'	-	-do-
Contract Section Team 'B'	-	-do-
Arch Section	-	-do-