

Tele: 23793509

Policy Letter No 24/2012

Directorate General Married
Accommodation Project (DG MAP)
Engineer-in-Chief's Branch,
Integrated HQ of MoD (Army)
Kashmir House, Rajaji Marg,
DHQ PO, New Delhi-110011

21379/Spec Ph-III/P&S/23/MAP

13 Jul 2012

(All PMs & DEPMCs)

SPECIFICATIONS: FIRST AID HOSE REEL (FIRE FIGHTING)

1. Refer this Headquarters letter No 21378/Vendor PH-III/P&S/03/MAP dt 29 Jun 2012
2. Given in the succeeding sub paragraph is the specification for first aid hose reel (fire fighting) for the future projects of MAP Phase-II & Phase-III:-

(a) The Hose Reel shall be drum type with hub wheel ties. The supply pipe shall be of copper and be a part of the suspension assembly. The drum shall rotate freely on the assembly. The drum shall be fabricated from GI sheet of minimum 18 guage thickness. The hose reel shall be directly tapped from the riser through a 25mm dia pipe, the drum and the reel being firmly held against the wall by use of dash fasteners. The Hose Reel shall be swinging type (180 degrees) and the entire drum, reel etc shall be as per and IS:884 including marking. The rubber tubing shall be of IS: 444 marked and rayon double braided. The nozzle shall be 6mm dia gun metal rotating head shut off type. A ball valve shall be used to shut off the water to the Hose Reel.

(JS Sodhi)
Lt Col
SO 1 (P&S)
for DG MAP

Internal

Team 'A'	-	for necessary action please
Team 'B'	-	-do-
Contract Section Team 'A'	-	-do-
Contract Section Team 'B'	-	-do-
Arch Section	-	-do-